



State of Vermont
PDD/Structures Design Section
National Life Building – Drawer 33
Montpelier, VT 05633-5001
www.aot.state.vt.us

Agency of Transportation

[phone] 802-828-2621
[fax] 802-828-3566
[ttd] 800-253-0191

Michie Corporation, Inc.
173 Buxton Industrial Drive
PO Box 870
Henniker, NH 03252

February 19, 2015

Project Name: Shrewsbury Project #: STP 1443(44)

Structure Identification: TH 4 Over Branch of the Mill River

The following Precast Concrete Structure (12' x12' x 120' Rigid Frame) and Precast Concrete Structure (Wingwalls 1 thru 4) details [Item 540.10, Precast Concrete Structures] for the above project (Vendor's Job # 5576) transmitted through SharePoint on February 2, 2015 have been reviewed and are being returned herewith.

Sheets: S1-S8 are to be reconsidered (note comments in red) and **resubmitted for final approval**.

We are missing the lifting loop design which we need to have submitted as part of the package and a concrete mix design. Please refer to the Section 540.04 Submittals of the Vermont Agency of Transportation Standard Specifications for Construction.

There shall be no fabrication done until all drawings have been approved.

Please remember that Jim Wild (802-828-6931) needs at least **Two weeks Advance Notification** with regards to fabrication dates of all the precast structures. Any material fabricated prior to the notification date is subject to rejection without further cause.

If you have any questions, please contact me at (802) 828-0048.

Sincerely,

Carolyn W. Carlson, PE

Attachments

cc: [X] Resident Engineer Tim Pockette
[X] Shop Inspector Jim Wild
[X] Contractor Casella Construction
[X] CWC

